

EU-Type Examination - Production Type Certificate

This is to certify that:

National Fire Fighting
Manufacturing Co Ltd
Plot No. S10201
Jebel Ali Free Zone South
P O Box 17014
Dubai
United Arab Emirates

Holds Certificate Number:

CE 623004

In respect of:


Mobile LP Fire Extinguisher assemblies as described in Technical File No. NF/PED/LP-MOB/01 Rev.00

On the basis of our examination under the requirements of Council Directive 2014/68/EU Module B of the Pressure Equipment Directive, as transposed into the law of The Netherlands Warenwetbesluit drukapparatuur 2016.

For and on behalf of BSI, a Notified
Body for the above Directive
(Notified Body Number 2797):

Previous Notified Body: BSI 0086

First Issued: 2018-04-26



Drs. Dave Hagenaaars, Managing Director

Latest Issue: 2019-11-27

Expiry Date: 2028-04-25

EU-Type Examination - Production Type Certificate

No. CE 623004

Additional Information

Limitations of Certificate Validity

Products: Mobile LP fire extinguisher assemblies in the following models: -

NTP25 – 25 kg Dry Powder – PS = 21.0 bar g and TS = -20°C to +60°C

NTP50 – 50 kg Dry Powder – PS = 21.0 bar g and TS = -20°C to +60°C

NTP100 – 100 kg Dry Powder – PS = 21.0 bar g and TS = -20°C to +60°C

NTPS25 – 25 kg Dry Powder (Potassium Bi-carb.) – PS = 21.0 bar g and TS = -20°C to +60°C

NTPS50 – 50 kg Dry Powder (Potassium Bi-carb.) – PS = 21.0 bar g and TS = -20°C to +60°C

NTPS100 – 100 kg Dry Powder (Potassium Bi-carb.) – PS = 21.0 bar g and TS = -20°C to +60°C

NTFC50X – 50 Litre Foam – PS – 18.5 bar g and TS = 5°C to +60°C

NTFC100X – 100 Litre Foam – PS – 18.5 bar g and TS = 5°C to +60°C

NTFC135X – 135 Litre Foam – PS – 18.5 bar g and TS = 5°C to +60°C

As described in technical file no. NF/PED/LP/MOB/01 Rev.00

First Issued: 2018-04-26

Latest Issue: 2019-11-27

Expiry Date: 2028-04-25

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.

To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.