

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	National Fire Fighting MFG. FZCO (NAFFCO)	Client ID	102154
Company Other Name	NAFFCO	Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.5-2007 : Portable fire extinguishers - Specific requirements for powder type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	14/10/2018	Certification Expiry Date	14/10/2023
Certificate Issue Date	22/09/2013	Certificate Last Update Date	1/02/2019

APPROVED COMPANY/SITE ADDRESS(ES):

Between 6th and 7th Roundabouts Jebel Ali Freezone - Dubai United Arab Emirates

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Unique Certificate Code: **BBDEC97BAA0DDF2CCA2583260054BB93**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
1 NP-A	1.0 Kg Dry Powder Extinguisher	NAFFCO	1.0 Kg Dry powder, Rating: 1A:20B:C:E, FERN: 2154.05-01	18/08/2015
2.1 NP-A	2.1 Kg Dry Powder Extinguisher	NAFFCO	2.1 Kg Dry Powder, Rating: 2A:20B:C:E, FERN: 2154.05-02	18/08/2015
2.5 NP-A	2.5 Kg Dry Powder Extinguisher	NAFFCO	2.5 Kg Dry Powder, Rating: 3A:40B:C:E, FERN: 2154.05-05	18/08/2015
3 NP-A	3.0 Kg Dry Powder Extinguisher	NAFFCO	3.0 Kg Dry Powder, Rating: 3A:40B:C:E, FERN: 2154.05-03	18/08/2015
4.5 NP-A	4.5 Kg Dry Powder Extinguisher	NAFFCO	4.5 Kg Dry Powder, Rating: 4A:60B:C:E, FERN: 2154.05-04	18/08/2015

Comments:

Constructions of all listed extinguishers comply with standard AS/NZS 1841.1 General Requirements

End of the document



Certification Manager

