

# Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	<b>National Fire Fighting MFG. FZCO (NAFFCO)</b>	Client ID	<b>102154</b>
Company Other Name	<b>NAFFCO</b>	Type of Certification	<b>Product Certification; System 5</b>
Certification Standard	<b>AS/NZS 1841.4-2007 : Portable fire extinguishers - Specific requirements for foam type extinguishers</b>		
Scheme	<b>Global-Mark Product Conformance Scheme</b>		
Certification Review Date	<b>14/10/2018</b>	Certification Expiry Date	<b>14/10/2023</b>
Certificate Issue Date	<b>23/06/2014</b>	Certificate Last Update Date	<b>1/02/2019</b>

**APPROVED COMPANY/SITE ADDRESS(ES):**

**Between 6th and 7th Roundabouts Jebel Ali Freezone - Dubai United Arab Emirates**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**

Unique Certificate Code: **A8664EF0B345254FCA2583260054A92D**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®





**Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:**

*In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).*

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
6 NF-A	6.0L Foam Extinguisher	NAFFCO	6.0 L Foam, Rating: 3A:10B, FERN: 2154.04-02	1/06/2014
9 NF-A	9.0L Foam Extinguisher	NAFFCO	9.0 L Foam, Rating: 3A:20B, FERN: 2154.04-01	1/06/2014
9 NFS-A	9.0L Foam Extinguisher	NAFFCO	9.0 L Foam, Rating: 3A:20B, FERN: 2154.04-03	18/08/2015

**Comments:**

Constructions of all listed extinguishers comply with standard AS/NZS 1841.1 General Requirements

**End of the document**



**Certification Manager**