

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	National Fire Fighting MFG. FZCO (NAFFCO)	Client ID	102154
Company Other Name	NAFFCO	Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.2-2007 : Portable fire extinguishers - Specific requirements for water type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	14/10/2018	Certification Expiry Date	14/10/2023
Certificate Issue Date	23/06/2014	Certificate Last Update Date	25/08/2015

APPROVED COMPANY/SITE ADDRESS(ES):

Between 6th and 7th Roundabouts Jebel Ali Freezone - Dubai United Arab Emirates

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Unique Certificate Code: **6DBD4C99DEA5029ACA258326005461AD**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®





Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
9 NW-A	9.0L Water Extinguisher	NAFFCO	9.0 L Water, Rating: 3A, FERN: 2154.02-01	18/08/2015
9 NWS-A	9.0L Water Extinguisher	NAFFCO	9.0 L Water, Rating: 3A, FERN: 2154.02-02	18/08/2015

Comments:

Constructions of all listed extinguishers comply with standard AS/NZS 1841.1 General Requirements

End of the document



Certification Manager