## Prevention Certification



# This is to certify

#### NATIONAL FIRE FIGHTING MANUFACTURING COMPANY LIMITED

PO Box 17014, Jebel Ali, Dubai, U.A.E.

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

## Semi rigid hoses for fixed systems

(Refer to attached appendix for details)

which have complied with the requirements of the following:

BS EN 694:2001 Fire-fighting hoses -Semi-rigid hoses for fixed systems

Certificate No. 463h

Issue No. 01

Date of Issue

19 March 2008

This certificate is valid until withdrawn by LPCB. To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

S N Bird

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100 Fax +44 (0)1923 664603 www.RedBookLive.com This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions

and is maintained and held in force through regular surveillance activities

# Loss Prevention Certification Board



#### APPENDIX TO CERTIFICATE NO. 463h

### NATIONAL FIRE FIGHTING MANUFACTURING COMPANY LIMITED

Model	Description	LPCB Ref. No.
NF-RH-19R	Semi rigid hose, 19 mm, colour red	463h/01
NF-RH-25R	Semi rigid hose, 25 mm, colour red	463h/02

Notes

1) Maximum working pressure is 1.2 MPa (12 bar).

This certificate is valid until withdrawn by LPCB.

To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

S: 3:

Page 2 of 2

Date of Issue 19 March 2008

Issue No. 01

S N Bird

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.