



Certificate of Compliance

This certificate is issued for the following:

FIRE HYDRANTS (DRY BARREL TYPE) FOR PRIVATE FIRE SERVICE

<i>Model</i>	<i>Size, inch (mm)</i>	<i>Hose Outlets, inch (mm)</i>	<i>Pumper Connection, inch (mm)</i>
150-NFH(M), Traffic Type	6 (152)	Two - 2 ½ (64)	4 ½ (114)
150-NFH(F), Traffic Type	6 (152)	Two - 2 ½ (64)	4 ½ (114)

Prepared for:

National Fire Fighting Mfg FZCo
PO Box 17014
Jebel Ali Free Zone, Dubai
United Arab Emirates

FM Approvals Class: 1510

Approval Identification: 0003055633

Approval Granted: June 29, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group