

Loss Prevention Certification Board



This is to certify

NATIONAL FIRE FIGHTING MANUFACTURING COMPANY LIMITED

PO Box 17014, Jebel Ali, Dubai, U.A.E.

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

Layflat delivery hoses

(Refer to attached appendix for details)

which have complied with the requirements of the following:

BS 6391:1983 Non-percolating layflat delivery hoses and hose assemblies for fire fighting purposes

Certificate No. 463g

Issue No. 01

Date of Issue 19 March 2008

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

S N Bird



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 463g

NATIONAL FIRE FIGHTING MANUFACTURING COMPANY LIMITED

Model	Description	LPCB Ref. No.
NF-DH2 65R	2.5" Layflat delivery hose, colour red	463g/01
NF-DH2 65W	2.5" Layflat delivery hose, colour white	463g/02

Notes:

- 1) Maximum working pressure is 15 bar, maximum nominal length 36m.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

S N Bird

Page 2 of 2

Date of Issue 19 March 2008

Issue No. 01

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.