


LIQUID LEVEL INDICATOR (LLI)

DESCRIPTION

Clean Agent Containers are used in fire extinguishing systems to store the Clean Agent until fire develops and the agent must be released. The Clean Agent is retained in the container by an Impulse Valve assembly which contains a fast-acting rupture disc. The disc will be ruptured, and the Clean Agent released, through the operation of an actuator by an electric signal that is automatically, manually or pneumatically controlled.

FEATURES

- Provides a means of verifying the weight of agent in a container without having to remove the container and weigh it on a calibrated scale.
- Enables the inspector to determine the weight of agent with the container safely secured in its installed position.
- Furnished on the 150, 215, 375, 650 and 1000 lb. (44, 61, 88, 153, 267 and 423 L) containers.



SPECIFICATION

Container Size Lb. (L)	LLI Part Number
100 (44)	NF-70-1353-27
150 (61)	NF-70-1353-14
215 (88)	NF-70-1353-18
375 (153)	NF-70-1353-27
650 (267)	NF-70-1353-38
1000 (423)	NF-70-1353-49
Listings and approvals	UL listed & FM Approved