

CERTIFICATE OF COMPLIANCE

Certificate Number 20170508-R25075
Report Reference R25075-20130830
Issue Date 2017-MAY-08

Issued to: NATIONAL FIRE FIGHTING MFG FZ CO
PO BOX 17014
JEBEL ALI FREE ZONE
DUBAI UNITED ARAB EMIRATES

**This is to certify that
representative samples of**

SWINGING-TYPE FIRE DOORS; SWINGING-TYPE FIRE
DOORS, POSITIVE-PRESSURE TESTED

Model EAGLE, single and pair of Swinging-type fire door
assembly of the steel covered composite type with
honeycomb core construction, intended for 2h (where
applicable), 1-1/2h, 1h and 3/4h locations for use in
masonry constructions


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10B, Fire Tests of Door Assemblies
ANSI/UL 10C, Positive Pressure Fire Tests of Door
Assemblies

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

