

# CERTIFICATE OF COMPLIANCE

**Certificate Number** R25075  
**Report Reference** R25075-20221031  
**Date** 2022-November-09

**Issued to:** NATIONAL FIRE FIGHTING MFG FZ CO  
PO BOX 17014  
JEBEL ALI FREE ZONE  
DUBAI AE

**This is to certify that representative samples of** SWINGING-TYPE FIRE DOORS  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 10C, Positive Pressure of Fire Tests of Door Assemblies  
ANSI/UL 10B, Fire Tests of Door Assemblies

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** R25075  
**Report Reference** R25075-20221031  
**Date** 2022-November-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USC – Model FALCON-X, Pair of Swinging-type fire door assembly of the hollow-metal steel stiffened type with rockwool insulation core, intended for 3h, 2h (where applicable), 1-1/2h, 1h and 3/4h locations, 30 min 450°F Temperature Rise Rating, for use in masonry constructions.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

