

# CERTIFICATE OF COMPLIANCE

**Certificate Number** R40527  
**Report Reference** R40527-20210628  
**Date** 2021-August-27

**Issued to:** NATIONAL FIRE FIGHTING MFG FZ CO  
PO BOX 17014  
JEBEL ALI FREE ZONE  
DUBAI AE

**This is to certify that representative samples of** FIRE-PROTECTIVE CURTAINS  
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** ANSI/UL 10D, Standard for Fire Tests of Fire Protective Curtain Assemblies

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE


**Certificate Number** R40527  
**Report Reference** R40527-20210628  
**Date** 2021-August-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

**Models:**

USC – Model NFC-SB100, Single Barrel, Fire-Protective Curtains, surface or between-jamb mounted, rated up to and including 3 hr., for use in masonry wall type constructions, maximum 6 m (19.7 ft.) wide by 12 m (39.4 ft.) high.

USC – Model NFC-MB100, Multiple Barrel, Fire-Protective Curtains, surface or between-jamb mounted, rated up to and including 2 hr., for use in masonry wall type constructions, maximum 250 m (820 ft.) wide by 12 m (39.4 ft.) high.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

